

## Electrical Panel Permit Application & Inspection Checklist

Homeowner Edition — Use before applying and before your inspection | Free resource from panelpermitmap.pages.dev

Property Address:	_____
Parcel Number (APN):	_____
Permit Number:	_____
Permit Expiration:	_____
Building Dept. Phone:	_____
Utility Co. & Phone:	_____
Inspection Date/Time:	_____

### SECTION 1: BEFORE YOU APPLY

Complete before submitting permit application

- Property address confirmed — matches what will appear on application
- Parcel number (APN) obtained from county assessor's website or tax bill
- Current panel amperage identified (printed on main breaker)
- New panel amperage determined (100A / 150A / 200A / 400A)
- Panel manufacturer and model selected (if replacing)
- Project description written clearly: e.g. '200A residential service panel replacement'
- Owner-builder eligibility confirmed with local building department
- Owner-builder declaration form downloaded or located on permit portal
- Estimated project value calculated (\$1,500–\$5,000 typical range)
- Online permit portal account created (or in-person visit scheduled)
- Permit fee estimated and payment method ready

### SECTION 2: AFTER PERMIT APPROVAL

Before starting work

- Permit approved — confirmation received by email or portal
- Permit card printed and posted visibly at job site (front window or entry)
- Utility company contacted — service disconnect scheduled (allow 1–4 weeks)
- Utility disconnect date confirmed in writing or by phone

Panel working clearance verified: 30" wide x 36" deep x 78" high (NEC 110.26)

All materials purchased and on-hand (panel, breakers, grounding components, wire)

Materials are listed/labeled products (UL, ETL, or CSA listed)

## SECTION 3: INSTALLATION INSPECTION POINTS

Inspector will verify all items below

### Grounding & Bonding

Ground rod(s) installed — minimum 8 ft, #6 AWG or larger conductor to panel

Metal water pipe bond: #4 AWG within 5 ft of entry, bonded to panel ground bar

Neutral bar and ground bar BONDED at main panel (main bonding jumper installed)

Neutral bar and ground bar SEPARATED at any sub-panels (not bonded)

All grounding conductors are green, bare copper, or marked green

### Service Entrance & Panel Enclosure

Service entrance conductors properly sleeved in conduit or SE cable

Drip loop present on exterior service entrance conductors

Main breaker properly rated for service size (200A panel → 200A main breaker)

Panel enclosure is undamaged and fits the installation location properly

All unused knockouts closed with listed fillers (CRITICAL — commonly failed)

Dead front cover fits securely and can be safely removed

Panel clearances meet NEC 110.26 (30" x 36" x 78")

### Wiring & Connections

All wire connections tight — no loose terminals or stray strands

Conductors properly sized for their breakers (no undersized wire)

No aluminum wire on breakers rated for copper only (check for CO/ALR marking)

No double-tapped breakers (unless using listed tandem/duplex breaker)

Neutral conductors properly white or gray

### AFCI & GFCI Protection

AFCI breakers installed on all circuits required by local NEC edition (bedrooms minimum; NEC 2020: most habitable rooms)

GFCI protection present on bathroom circuits

GFCI protection on kitchen countertop receptacle circuits

GFCI protection on garage, outdoor, and wet-area circuits

## Labeling

- Every circuit labeled on directory card — no blank spaces or 'unknown' entries
- Panel directory card legible and permanently attached inside door
- Panel nameplate (manufacturer, amperage, voltage rating) visible

## SECTION 4: DAY OF INSPECTION

Have everything ready before  
inspector arrives

- Permit card posted visibly at entry, or permit number ready to provide
- Panel area clear and accessible — no boxes, storage, or obstructions
- Dead front cover removed or ready to remove quickly
- All work is visible — no walls closed or work buried before inspection
- You or a knowledgeable person is present to answer inspector's questions
- Flashlight available for inspector's use if needed
- Utility company contact info on hand in case of questions

### 5 Most Common Inspection Failures:

1) Missing AFCI/GFCI breakers 2) Insufficient working clearance 3) Open knockouts 4) Unlabeled circuits 5) Grounding errors